



CE DECLARATION OF CONFORMITY

Under the Directive 2014/68 / EU

The manufacturer:
MARELI SYSTEMS LTD
Lyulin, bl.821, ap.1, Sofia, 1336, Bulgaria
Declares that the pressure equipment:

Main water tank V = 40-200 L :	
Product name:	BMS 40 - BMS 200
Working pressure Pp:	0.3Mpa
Test pressure Rpp:	0.42MPa
Testing environment:	water
Maximum permissible temperature Tmax:	95°C
Volume:	40-200L
Year of manufacture:	2022

Meets the requirements of “Directive 2014/68 / EC and assessment of pressure equipment composition”.

Method of conformity assessment applied: Internal H2 counter
Applied standards: EN13445-2,3,4,5, BDS EN ISO 14732, BDS EN ISO 15614

Other Standards and Decrees: 2014/68 / EU
Notified Body for Conformity Assessment: “ITEM CONSULT” Ltd., Sofia, index 1837.

PLACE: SOFIA

DATE: 08.03.2023

SIGNATURE: _____

